

zenon manual

straton

v.6.51





© 2010 Ing. Punzenberger COPA-DATA GmbH

All rights reserved.

Distribution and/or reproduction of this document or parts thereof in any form are permitted solely with the written permission of the company COPA-DATA. The technical data contained herein has been provided solely for informational purposes and is not legally binding. Subject to change, technical or otherwise.

Contents

1. Welcome to COPA-DATA help.....	1
2. straton	2
3. Basics straton Workbench (IEC 61131-3).....	3
3.1 General information about this help chapter.....	3
3.2 straton General.....	4
3.3 straton toolbar and context menu detail view.....	5
3.4 First steps with straton in zenon.....	6
3.4.1 Create a straton project in a zenon project.....	6
3.4.2 Edit a straton project	9
3.4.3 Design of the Workbench.....	9
3.5 Variable handling	10
3.5.1 Create O and M variables in straton	11
3.5.2 Create O and M variables in zenon.....	14
3.5.3 Using zenon variables in straton	15
3.5.4 Variable names.....	19
3.6 Arrays.....	21
3.7 Data structures	21
3.8 Distributed engineering (multiuser).....	22
3.9 Reusing projects	23
4. straton Workbench	24
5. straton Runtime (Soft PLC)	25
5.1 User interface	25
5.1.1 Slider Allowed maximum.....	26
5.1.2 Settings	27
5.1.3 Messages	32
5.2 Licensing.....	33
5.2.1 Demo mode	34

5.3	Start the straton Runtime	34
5.4	straton Runtime cycle	38
5.5	Close the straton Runtime.....	40
5.6	Remote systems	41
5.6.1	zenon Runtime and straton Runtime on one remote PC.....	42
5.6.2	straton Runtime autarkic (PC)	42
5.7	straton Runtime with Real Time Kernel (RTK).....	43
5.7.1	Restrictions and requirements of the straton RTK.....	47
5.7.2	straton RTK configuration	49
5.7.3	Blue Screen Handling.....	56
5.7.4	Error codes when starting stratonRTK	57
5.8	Redundancy straton and zenon	60
5.8.1	Requirements	60
5.8.2	Configure redundancy	62
5.9	OEM spezifikation.....	65
5.10	straton I/O driver support	68
5.11	straton I/O driver: Hot-Restart/Online Change	70
6.	straton Runtime Manager	72
6.1	Why should you use the straton Runtime Manager?.....	72
6.2	Main menu	72
6.3	Properties help	73
6.3.1	Configuration list	73
6.3.2	straton project folder	73
6.3.3	Name of the configuration.....	73
6.3.4	Port (Main).....	74
6.3.5	Port (Binding)	74
6.3.6	Startup	75
6.3.7	Start in step mode.....	75
6.3.8	Windows real time priority.....	75
6.3.9	Hard real time	76
6.3.10	Report output	76
6.3.11	Auto start.....	77
6.3.12	Button "New"	78
6.3.13	Button "Edit"	78

6.3.14 Button "Save"	78
6.3.15 Button "Delete"	78
6.3.16 Button "Start"	78
6.3.17 straton Runtime (settings)	79
6.3.18 Language selection (languages)	79
6.3.19 Show splash screen (setting)	79

1. Welcome to COPA-DATA help

GENERAL HELP

If you miss any information in this help chapter or have any suggestions for additions, please feel free to contact us via e-mail: documentation@copadata.com (mailto:documentation@copadata.com).

PROJECT SUPPORT

If you have concrete questions relating to your project, please feel free to contact the support team via e-mail: support@copadata.com (mailto:support@copadata.com)

LICENSES AND MODULES

If you realize that you need additional licenses or modules, please feel free to contact the sales team via e-mail: sales@copadata.com (mailto:sales@copadata.com)

2. straton

straton is the programming environment in accordance with IEC 61131 included in zenon. It is available as ***Editor***(on page 3) and ***Runtime (Soft-PLC)***(on page 25).

3. Basics straton Workbench (IEC 61131-3)

straton is an IEC 61131-3 programming environment for different target systems with straton Runtime kernel. In the case of zenon, the straton Runtime kernel is designed as a soft PLC for PC and CE platforms.

With straton development environment - the Workbench - PLCs can be engineered and programmed in the five defined languages of IEC 61131-3.

PROJECT MANAGER CONTEXT MENU

Menu item	Action
New straton project	Opens the assistant to create a new straton project.
Import XML...	Imports entries from an XML file.
Import external straton project...	Opens the dialog to select a straton project folder.
Editor profiles	Opens the drop-down list that includes pre-defined editor profiles.
Help	Opens online help.

3.1 General information about this help chapter

This manual provides a quick introduction in the use of straton in combination with the integrated solution with zenon. This manual does not provide an instruction into computer languages, functions and function blocks. For this use the extensive help included directly in the **straton Workbench** (Main.chm::/K5HELP.chm::/K5HELP.htm) (IEC 61131-3 programming environment).

The straton Workbench provides an extensive help functionality. In order to access this help function, open the entry **Help** in the menu of the straton Workbench or click **here** (Main.chm::/K5HELP.chm::/K5HELP.htm). In order to access a help chapter about a certain topic (e.g. function block), select it with a mouse click and then press F1.

The in zenon integrated straton Workbench has not TAG limitation independent of I/O or TAG extension of the zenon Editor.

3.2 straton General

straton is an IEC 61131-3 programming environment for different target systems with straton Runtime kernel. In case of zenon the straton Runtim kernel is designed as a soft PLC for PC and CE platforms.

STRATON WORKBENCH

The straton Workbench is the tool for programming the straton PLC. The straton Workbench ios started in the zenon Editor. All five IEC 61131-3 predefined languages are available.

Abbreviation	Long form of the language
SFC	Sequential Function Chart
FBD	Function Block Diagram
LD	Ladder Diagram
ST	ST – Structured Text
IL	Instruction List

IEC 61131-3

Part three of the IEC 61131 descubes the syntax and semantic of compuer languages for PLCs which have been defined in part 1 of the IEC 61131.

STRATON RUNTIME

The straton Runtime is the target system and executes the compiled code of the straton Workbench. The straton soft PLC is available for the PC (Windows® XP, XPe, Vista, Server) and for Windows® CE platforms. Beside the soft PLC there are also hard PLCs, which have implemented the straton Runtime kernel as OEM software. The manufacturers of these hardware PLCs can be found on www.copalp.com (<http://www.copalp.com>).

You can find more information about straton here: **straton Runtime (Soft PLC)** (on page 25)

3.3 straton toolbar and context menu detail view



CONTEXT MENU


Menu item	Action
New straton project	Opens the dialog to <i>create a new project</i> (on page 6), create it in the list and opens the straton Workbench with the new project.
Open straton project in Workbench	Opens the selected project in straton Workbench.
Delete	Deletes selected entries after a confirmation message.
Edit selected cell	Opens the selected cell for editing. The binocular symbol in the header shows which cell has been selected in a highlighted line.
Replace text in selected column	Opens the dialog for searching and replacing texts.
Properties	Opens the Properties window for the selected entry.
Import XML	Imports from an XML file.
Import external straton project	Opens a window to select the project folder.
Remove all filters	Removes all filter settings.
Help	Opens online help.

3.4 First steps with straton in zenon


Here the first steps in order to create a straton project in zenon are explained. In addition information is given on how to configure and edit the project in zenon. If this is your first contact to straton in zenon, go through this introduction step by step.

3.4.1 Create a straton project in a zenon project

After creating a zenon workspace and a zenon project (see also: Project and workspace) you can find the module **straton (IEC 61131-3)** in the Project manager. With a right mouse click on straton (IEC 61131-3) or in the detail view of the project manager the entry **New straton Project ...** can be selected in the context menu. By clicking the straton project new icon in the detail view of the project manager in order to perform the same action.



With this command the following window appears:



Here, you can give the straton project a freely definable name.

Hint: The Name

- ▶ consists of alphabetic characters
- ▶ must not exceed 15 characters
- ▶ must not be empty
- ▶ must only contain valid characters:
 - invalid characters are: all numbers and special characters such as \ / , ; ß ä ö ü : * ? " < > | ()
 - a dot may only be used within the name not at the beginning of the name

Button **Finish** is only active if a valid name was entered.

Select *STRATON32* or *IEC870* as driver. This selection defines the eventual Runtime communication between straton and zenon. In addition the creation of the operating and monitoring (O and M) variables is based on this: Based on the name when using the STRATON32 -driver, based on the address when using the IEC870 -driver

Attention

If you have selected a driver once, you cannot change it afterwards.



Info - Decision guidance for the driver selection

- ▶ STRATON32 driver: This driver is based on Ethernet TCP/IP. Its advantages are that you can operate it cyclically or on change. Referring to the integrated solution (straton in zenon) another

advantages is that complex data types (structured data types and arrays) are supported.

- ▶ IEC870 driver: This driver is mostly used in the infrastructure automation. You can operate it serial (-101) or over Ethernet TCP/IP (-104). It generally uses on change data traffic. Complex data types are not supported.
 - ▶ IEC850 driver: It is the successor of the IEC60870 standard and is completely object-orientated.

Click on **Finish** in order to apply the selected driver.


For information about the configuration take a look at the corresponding driver help:

STRATON32 driver: STRATON32

IEC870 driver: *IEC870* (Main.chm::/IEC870.chm::/IEC870.htm)

IEC850 driver: IEC850

Now a straton project is created with the name you chose. The straton Workbench is started automatically.



You can now start with the engineering/programming of your PLC!

Info

Keep in mind that a new straton project already has a few default values in the project properties. Make sure that these values meet for requirements. Change the project settings where appropriate. In order to do this open the project settings in the Workbench under **Project/Settings**....


You adjust the properties of the straton projects in the zenon project in the properties window of the zenon Editor. You will find a description of the single properties in the property help.

3.4.2 Edit a straton project

With a double click on the project or the context menu, you can open an existing straton project for editing. Alternatively you can click the corresponding icon in the toolbar in the details window.

3.4.3 Design of the Workbench

The straton Workbench can be divided in the following areas:



Range	Description
1	In this section documents are displayed and edited (programs, watch lists, ...).
2	The workspace: Documents are created and opened in this list.
3	The output window displays messages and provides diagnosis tools.
4	In the variable editor variables and instances are declared.
5	The property tab and the Z arrangement are used for the engineering of the graphics documents.

6	The tab Libraries lists all available functions and function blocks
7	The tab Spy list displays the online values of selected variables during the debugging.
8	The tab Definitions displays all definitions.
9	The tab Graphics lists all graphical objects.

Each section (except section 1) can be shown and hidden with commands from the menu **Views**.

In the central area you will find the documents of the workspace. If several documents are opened at the same time, you can switch between the different documents using the tab at the bottom. With button **x** in the header the active document can be closed.

The variable editor and the document area in the center can be maximized at any time with the corresponding button (blue symbol with white line) or a double-click on the header.

If several documents are open in the central area, one of these can be fixed in the top or left part. In order to do this right click the corresponding tab and select **Fix**. With the same menu you can unfix the document at any time and fix another one:

3.5 Variable handling

The intelligent integration of straton in zenon offers considerable advantages in engineering PLC and SCADA projects. The O&M variables (operating and monitoring) from the PLC system are available in zenon with just a few mouse clicks. When changing the variable (name, datatype, ...) these changes are immediately passed on the other system.

The advantage of the integration:

- ▶ Easy handling of O&M variables
- ▶ Immediate alignment of changes
- ▶ Saving of labor because of omission of import/export
- ▶ Increased quality by minimizing causes for errors

⚠ Attention

External UDFBs from other straton projects are not part of the straton project and therefore not available in zenon.

3.5.1 Create O and M variables in straton

All variables created in the straton Workbench can be marked as O&M (operating and monitoring) variables:

- ▶ Local program variables
- ▶ Global variables
- ▶ Retain variables (=remanent variables)
- ▶ Array variables
- ▶ Structure variables
- ▶ UDFB instances (User Defined Function Block)

⚠ Attention

We recommend that when using UDFB instances as O&M variables to administrate only one straton project in a zenon project.

If two or more straton projects are administrated in zenon, the as O&M marked UDFBs appear as structure data types.

⚠ Attention


A soon as a straton variable is declared as an O&M variable, you must avoid editing straton variables in the Workbench as text!

This leads to the loss of variable declarations.

In order to do this the following steps are necessary:

(Refer to the online help of the straton Workbench for the exact steps to create a variable in straton.)


1. Right click on a variable in the variable list.
2. Select **Properties** from the context menu.
3. Activate checkbox **Embed symbol** in the following dialog.
4. Change the profile in the combo box from *None* to *STRATON (*Operating and Monitoring for zenon*)*.
5. Click on OK.



Now the O&M variable has been entered in the zenon variable list. The O&M variable is displayed with a prefix in zenon. The prefix has the following structure:

<straton project name>/<straton program name or global or retain>/<variable name>

You can set the profile and the flag directly in the variable list of straton. Thus you do not have to open the context menu and the dialog.



Mark the line **Properties** of the corresponding variable. Press **Ctrl+F12**. Thus the profile straton is displayed in this line. In addition you must activate the checkbox for embedding the symbol via double click or **Enter** in column **Symb..**

Attention

*The checkbox **Embed symbol** must be activated. Variables for which this checkbox is not active are not able to communicate with zenon using the STARTON32 driver and will not supply any values.*

ADDITIONAL ATTRIBUTES OF THE VARIABLE

The additional attributes **Identification** and **Description** of a variable are also displayed in zenon when you select the profile STRATON (*Operating and Monitoring for zenon*). In zenon the contents of identification and description can be found in the variable properties **Identification** and **Resource label**.

ARRAYS AND STRUCTURE VARIABLES

If arrays or structure variables are marked with the profile STRATON (*Operating and Monitoring for zenon*), they are also displayed in the variable list in zenon. You must however activate the desired elements of the variable.

UDFB INSTANCES

UDFB instances which are marked with profile STRATON (*Operating and Monitoring for zenon*), they are not automatically available in zenon. In case you want them to be available, you must activate this functionality manually with the help of the following entry in file K5DBK.INI. In file K5DBK.INI scroll to section [XS] and enter

ShareUDFBDatatype=1

.

If you deactivate this entry, existing UDFB data types in a project are still modified. However no new UDFBs are created.

HARDWARE IO DECLARATIONS

straton IO variables can be used zenon if in the straton Workbench they:

- ▶ have a profile

- ▶ have an alias name; this name is used in zenon instead of `%IX0.0` (board type, board index, bit number)


An alias is necessary if the straton profile is used and property **Embed symbol** was activated. In this case the variable is also available in zenon (Editor and Runtime).

Attention:

- ▶ IO variables cannot be renamed in zenon.
- ▶ IO variables for straton IO cards cannot be created in zenon.
- ▶ The data type of IO variables should not be changed in zenon: Changes are not adopted in the straton Workbench.
- ▶ Changes to the hardware IO declaration should always be carried out in straton. In zenon no new variable for the straton32 driver can be created as hardware I/O variable for straton.

3.5.2 Create O and M variables in zenon

O&M (operating and monitoring) variables for the soft PLC straton can also be declared in zenon. In order to do this create a variable in zenon as usual:



Attention

*Take care that the naming convention is IEC 61131-3 compatible (no special characters, ...); otherwise the button **Finish** will not be available in the dialog. See also: [Variable names](#) (on page 19)*

Info


The variables declared in zenon are always entered in the Global area of the variable list in straton.

3.5.3 Using zenon variables in straton

It is very easy to further process variables from PLC systems such as e.g. Siemens S7 or Beckhoff TwinCAT in straton, variables which were read in by the according zenon drivers in zenon.

One possibility to realize this functionality is the allocations (see Allocations). The variable from the PLC (e.g. S7) is linked to a straton variable with an allocation. In this case only a unidirectional communication is possible.

PLC variables (e.g. from a S7) can be exchanged between zenon and straton via a shared memory connection bidirectionally (!), easier and quicker. In the properties of the PLC variable the flag **Externally visible** has to be set to make the variable available in the straton Workbench.



The screenshot shows two windows from the straton Workbench interface.

Project Manager Window: This window displays a tree view of the workspace structure under "Workspace D:\WORKSPACE\IPA [Start project]". The tree includes categories like Variables, Pictures, Functions, Language table, Archive server, Recipes, Time control, Scripting, STRATON (IEC 6113...), Scheduler, Interlockings, Message Control, Menus, Report Generator, User, Files, History of changes, Project backups, PRO_01, and MULTI_USER. A global symbol library is also listed. On the right, a table lists variables with columns for Status, Name, and Identification. One entry, "Internal_UINT_001", is selected. Below the table, a message indicates 27 total / 1 filtered / 1 selected / 3 tags used / ur.

Property Dialog Window: This window is titled "Property: IPA - Variable". It contains a list of properties for the variable "Internal_UINT_001". The properties include:

ext. address parameters	
external init value	
external profile name	
external read/write	<input checked="" type="checkbox"/>
external variable group	
externally visible	<input type="checkbox"/>
HD active	<input type="checkbox"/>
Hysteresis	
Identification	
Initial value	0
Logging in CEL	
Max. set value	65535
Min. set value	0
Name	Internal_UINT_001
Net address	0
Number of values	0
Offset	0
Picture alarm	


As soon as this flag is set, the variable is displayed in the variable list of the straton Workbench.

⚠ Attention

*Regard interactions with property **Hysteresis**:*

If a **Hysteresis** was configured for the zenon variable, the value in straton does not match the value in the PLC. It is also possible that it does not match the value in zenon:

- ▶ If the value changes in the PLC and stays within the configured hysteresis, it is not communicated to the zenon Runtime and therefore also not to straton.
 - ▶ If the value is changed by the user in zenon (e.g. via a function) and the value stays within the configured hysteresis, the value remains the same in zenon and in straton but it changes in the PLC.
 - ▶ If the value is changed in straton and stays within the hysteresis, the value in the PLC and in straton changes. It remains however the same in zenon.
- If in this situation the value changes in the PLC and stays within the hysteresis, three different values exist.
- one in the PLC, one in zenon and one in straton.



Such a variable is especially marked in straton, as it cannot be changed in straton. Changing the variable here would lead to problems, as the source of the variable is the PLC programming environment in the external PLC (e.g. S7).


⚠ Attention

Be careful with the variable name! The name of the variable from an external PLC has to be IEC 61131-3 compatible. Also see [Variable names](#) (on page 19).


In straton a so-called I/O driver - shared memory driver - must be loaded in order to make the communication for such variable possible in the Runtime.

In order to do this open the fieldbus configuration in the straton Workbench with *File -> Open... -> Fieldbus configuration.*

The following dialog opens with the menu *Insert -> Insert configuration...:*



Here select the configuration *straton to zenon-RT* connection. So this configuration is inserted in the tree of the fieldbus configuration:



Now it is guaranteed that the externally visible variables from zenon communicate with straton.

Info

Please be aware, that such a connection only works locally on a PC or a CE device. Here it is not possible to communicate with a straton Runtime on another device.

ARRAYS AND STRUCTURE VARIABLES

With the help of the zenrt driver complex variables (arrays and structure variables) are resolved into a flat structure. The values of variables with the same name in straton and zenon are exchanged via the shared memory driver.

Info

The functions for checking the status of a variable and for setting Dirty are not supported at the moment.

The status information (time stamp and status bits) are not supported for complex data types.

If you marked an element of an array or a structure variable as externally visible, a simple variable with the same name is created in the straton Workbench. If you marked the array or the structure variable itself as externally visible, this complex variable is created in the workbench.

Info

If you mark an array or a structure variable as externally visible, the individual elements are not created in the Workbench anymore.

You can create variables in the workbench, which contain characters '.' or '[]' in their name. Therefore you can create variables which have the same name as variables which derive from an array or a structure variable. In this case the communication with the zenrt driver is not possible as no distinct allocation can be made.

3.5.4 Variable names

In straton variable names must be in accordance with the IEC 61131-3 regulations. The correctness of the entry is checked by zenon as well as by straton (communication take place using the STRATON32 driver).

For variables of other drivers (e.g. S7 TCO/IP driver), the engineer has to check that the variable name fulfills the regulations of the IEC 61131-3 (communication takes place using shared memory).

EXAMPLES FOR THE IEC 61131-3 NOTATION

Permitted name	Impermissible name	Comment
_XYZ	__XYZ	Twice with Underscore
xy_z	xy__z	Twice with Underscore

xyz_	xyz__	Twice with Underscore
MotorOn	Motor On	space
Motor_On	Motor On	Slash
mw10	1mw10	Numeral/ number at the beginning
xyz	#xyz	Hash
_Motor1	_Motor 1	space
Disturbance	Disturbance	Umlaut/diphthong
Bridge	Bridge	Umlaut/diphthong
Mo_tor	Mo-tor	hyphen

Now it is possible to use variables which are following the IEC 61131-3 regulations (free variable names). Take care when using free variable names.

Follow these rules when using free variable names:

- ▶ The following characters are not allowed to be part of a variable name: '(*', '*)', '//', '{' and '}'
- ▶ Variable names are not allowed to start with '__' (two underscores)
- ▶ If free variable names are used when using programming language ST or IL, they must be between {}.
- ▶ If free variable names are used with structure of array, they must be between {}.
- ▶ Variables with free variable names with a basic data type can be used without {} in programming languages FBD and LD. They must be declared as **global** variables.
- ▶ Variables with the same name once with {} and once without {} are regarded as two different variables.

3.6 Arrays

Arrays can be created in zenon and straton for both systems. The declaration as O&M variable takes place as described in chapters *Creating O and M variables in straton* (on page 11) and *Creating O and M variables in zenon* (on page 14).

Take care when creating arrays in straton that you must activate the single elements in zenon.

When creating arrays in zenon, set the array start to 0. Thus the arrays have the same indices in both systems.

3.7 Data structures

Structure datatypes can be created in zenon or in the straton Workbench.

Info

*When creating structure data types in zenon the IEC 61131-3 naming convention has to be used otherwise the structure data type is not available in straton. Also see *Variable names* (on page 19). Here the spelling is not checked by zenon!*


Info

If you create structure data types in straton, they are always declared as linked in zenon.

Therefore it is better to create a structure data type in zenon because then you can decide whether you want a linked or a embedded data type.

3.8 Distributed engineering (multiuser)

It is possible that more than one engineer is working on one zenon project. Thus for example one engineer works on a straton project and another works on the zenon project.



VARIABLES

In distributed engineering O&m variables (operating and monitoring) are handled separately by the straton project.

You can create variables in straton as usual. If the variables should also be available in zenon, they have to be equipped with the corresponding property (embedded symbol, profile straton (*Operating and Monitoring for zenon*)). After that the variable is created in zenon. You can check it in for other engineers (apply changes). You cannot edit a checked in variable in the straton Workbench. It is marked accordingly in the straton variable list.

DRIVERS

straton drivers are attended separately in distributed engineering by the straton project. That means if you want to make changes, you have to check out the STRATON32 driver (enable changes).

STRATON PROJECTS

In order to edit a multi-user straton project, it has to be checked out (enable changes). After the engineering, the changes can be undone or accepted.

3.9 Reusing projects

straton projects which were created with the **stand-alone** Workbench of COPA-DATA can be integrated easily in a zenon project.

Select in the context menu of the detail view of the module **straton (IEC 61131-3)** menu item **External straton Import project...**. With this command you can indicate an existing straton project (mark folder) and integrate it in the existing zenon project.

Another possibility is the XML import. In the context menu of the detail view of the module **<CA_PRODUCTNAME > (IEC 61131-3)** you will find the command **Import XML**. Thus straton projects which were first exported in XML can easily be imported in the zenon project.

4. straton Workbench

In this area you can find the manual for the straton Workbench. It is only available as online help.


5. straton Runtime (Soft PLC)

The straton Runtime interprets the compiled PLC Code of the straton Workbench. Runtime runs on Windows 2000, XP and XP embedded PCs, VISTA and Windows CE platforms.

This chapter gives an overview of the use of the straton Runtime and the configuration tool straton Runtime Manager.

⚠ Attention


Due to performance issues the straton Runtime Version 6.22 SP0 Build 2 needs the straton driver for the same or earlier zenon versions. Earlier straton Runtime versions still work with all straton drivers.



5.1 User interface

Usually the straton Runtime can only be found as a symbol in the system tray. A double-click on the symbol with the green arrow or on menu item *Show* in the context menu opens the straton Runtime user interface.

Depending on the current status, the user interface displays different states (*running, step mode, break point(s), stopped*).



A bar chart shows the PLC load.

In addition to information about the status of the straton project running, the following actions can be executed in the straton Runtime user interface:

- ▶ Slider **Allowed maximum** of the **PLC resources**: set allowed maximum
- ▶ **Settings...** (on page 27) button : Makes configuration possible via three tabs
 - *General settings* (on page 27)
 - *Redundancy* (on page 29)
 - *Advanced users* (on page 30)
- ▶ **Start/Stop** button: opens the dialog to start Runtime or stops Runtime
- ▶ **Messages** (on page 32) button: opens and closes the message window

5.1.1 Slider Allowed maximum

The slider **Allowed maximum** is used to guarantee other applications which run on the same device - such as zenon - system resources.

With this slider the maximal allowed execution time related to the cycle time can be set. If with a set cycle time of 10 ms the slider is set to 50% the PLC cycle may take a maximum of 5ms. If the PLC cycle takes longer than 5 ms, the remaining calculation is done in the next cycle. So one cycle has to be omitted from the PLC. This results in a cycle overflow.

The slider can be set between 10% and 100% steplessly.

The bar graph (PLC load) shows, how high the PLC load is in relation to the setting of the slider. From this you can conclude how to set the slider for an optimal tuning.

PLC load high (Slider between 50 and 100%): Set slider towards 100% or increase cycle time.

5.1.2 Settings

The **settings** make it possible to configure the straton Runtime with the help of three tabs:


- ▶ General settings
- ▶ Redundancy
- ▶ Advanced users

General

In the tab **General** the different parameter of the straton Runtime can be changed:

Parameters	Effect
Communication	
Port (Main):	IP port of the straton Runtime for the cyclic data transfer (e.g. straton Workbench).
Port (Binding):	IP port of the straton Runtime for the on change data transfer (e.g. CA_PRODUCTNAME Workbench or binding).
Run-up	
No start. Open this box:	When the straton Runtime is started, first this box is opened.
Cold start:	Initialized run-up. Also retain variables are started initialized.
Cold start (loading of RETAIN variables):	Initialized run-up with current values of the retain variables.
Warm start:	Restart with all variable values from the last stop.
Delay [s]	Delays the start by the set number of seconds.

	Default: 0
Storage path RETAIN data	Here the file with the retain variables is stored. The default setting depends on whether the straton Runtime is started.
Real-time priority	Sets the straton Runtime process to the windows priority <i>Realtime</i> . If the flag is not set, it means priority <i>Normal</i> .
Start in step mode	Starts the straton Runtime and immediately stops it in debug mode.
Write messages to STRATONRTLOG.TXT	Error messages which were generated by the straton Runtime are saved in this file. Attention: Writing log files can influence the PLC cycle!



Info


If the straton Runtime has been started with the zenon Runtime or with the straton Runtime Manager, changes done in this user interface are not effective after a restart of the straton Runtime. Please make the changes as usual in the straton project properties of the zenon Editors or in the straton Runtime Manager.

In such cases the dialog helps to determine which parameters were forwarded to the straton Runtime.

The changes to the settings which were done in this dialog are only effective if the straton Runtime is started directly (e.g. using the Windows Explorer).

Redundancy

In tab **Redundancy** you can see the redundancy settings for the straton Runtime.



You can check or enter the following entries:


Entry	Meaning
Activate redundancy	Runtime runs in redundancy mode
Server port:	Port for replication connection
Server Time-out [ms]	Time-out in order to determine if the passive client is available. After the time-out expires, the replication is stopped.
Client Time-out [ms]	Time-out in order to determine that the active server is no longer available. After the time-out expires, the passive client becomes the active server.
Partner address:	IP address of the redundancy partner.

 **Info**

You can find details on configuring the redundancy of straton and zenon in chapter *Redundancy straton and zenon* (on page 60).

Advanced users

In the tab **Advanced** you carry out settings for the on change communication with external applications (Binding, zenon driver, ...).



The following settings are available:

Entry	Meaning	Range of values
System	Max. length of the system queue. In this queue e.g. overflows of the event queue are buffered.	1024 ... 65520 Default: 1024
Alarms	Length of the alarm queue (not used at the moment)	0 ... 65520 Default: 0

max. connections	Number of possible connections (cannot be changed)	4 ... 65535 Default: 256
Events	Length of the event queue: In this queue the events of the straton Runtime event servers are written. From there they are sent via TCP. If this queue overflows, the overflow messages are written in the system queue.	0 ... 65535 Default: 8192
Messages	Length of the info queue. In this queue the messages to the straton Workbench are buffered.	1024 ... 65520 Default: 32768
max. puffer	Buffer size of the events per cycle. This parameter defines how much many variables are handled by the event server per cycle.	128 ... 65535 Default: 1024
Reset	Restores the default settings	

Info


If in large projects more than 1024 variables are transferred between straton and zenon with the *straton32.exe* driver, the parameter **Max. buffer** must be increased accordingly. An easy method to find out the number of **Max. buffer** is the value for the compiled I/Os in the output window of straton compilers. See illustration below.

```
Build in progress... Please Wait...
>> Complex variables stored in a separate segment
>> Option not supported by runtime version 2.20 or older

Loading application symbols...
test
CounterX01
CounterX02
CounterX03
CounterX04
CounterX05
CounterX06
CounterX07
CounterX08
CounterX09
Building application data...
Warning: Compiled for OEM specific runtime: T5CD
< 132 BOOL/SINT; 1 INT; 11 DINT/REAL; 1 LINT/LREAL; 1 TIME; 1 STRING; - CRC = 2cfdf84 >
< CT Segment = 1 byte(s) >
< 129 I/Os >
Relocating code...
< Code CRC=a53de7dd · File CRC=2fe496f0 · Size=190568>
No error detected
```

5.1.3 Messages

Runtime messages can be displayed in the straton Runtime user interface. Click on the **Messages>>** button to activate the view. The message display opens. Click on the **Messages<<** button to close the message display.



For actions in the message display, click in the message display with the left or right mouse button. You obtain a context menu:

Menu entry	Description
Display time stamp of messages	Adds a time stamp to each message.
Copy messages to the clipboard	Copies selected entries to the clipboard.
Delete all messages	Deletes all messages from the message window.

You administer the settings for straton logging and the drivers with the diagnosis viewer. In doing so, each straton Runtime and each bus driver receives their own connection to the diagnosis server as a diagnosis client. This does not include obsolete drivers, for example those from a third-party manufacturer.

5.2 Licensing

INSTALLATION WITH ZENON (ZENON RUNTIME AND STRATON RUNTIME ON ONE PC)

The straton Runtime is automatically licenced with the zenon serial number. During the installation enter the serial number and the activation number in the according dialog. If no licence number is available, click on **Demo Version** (on page 34).

AUTARCHIC INSTALLATION (STRATON RUNTIME WITHOUT ZENON RUNTIME ON ONE PC)

For an autarkic installation (straton runs on a PC without the zenon Runtime) you can again enter the serial number and the activation number directly in the installation dialog.

LATER LICENSING WITH LICENCE ORDER

You also can do the licensing later with the Licence order. Open the license order in the Windows start menu under *Programs -> COPA-DATA -> Licensing*. For later licensing the serial number and the activation number are entered in this dialog. The procedure is finished with OK.


For soft-licensing the so-called licence number must be read from the hardware configuration of your PC. Click the button for soft licensing and follow the requests in the following dialogs.

AFTERWARDS LICENSING USING THE ZENON EDITOR

In the zenon Editor you can open the dialog for licensing using *File -> Standard configuration -> License product....* You can enter the serial number and the activation key here.

INFORMATION ABOUT THE LICENSE OF THE STRATON RUNTIME

Open the user interface of the straton Runtime by clicking on the straton Runtime icon in the system tray. Then click on the top left corner and select **About STRATONRT....** A window appears with information about version and license of the straton Runtime.



5.2.1 Demo mode

straton Runtime starts in Demo Mode if you enter a false (or no) serial number or a false (or no) activation key or if no dongel is connected. The Demo Mode stops the straton Runtime after 15 minutes. With a special demo serial number the straton Runtime runs continuously for 30 days. After these 30 days then the maximal time of the straton Runtime is again 15 minutes.

STRATON MINI

You did not buy the straton Runtime license but you own a valid zenon Runtime license. Then a mini version of the straton Runtime is licensed automatically. With the mini version up to eight TAGs (=variables) can be used by straton via input/output mechanisms. TAGs are variables of field bus drivers and variables with profiles (e.g. B&B profile straton).

Calculation example:

- ▶ four variables for the communication straton <= > zenon
- ▶ four variables for the communication straton <= > Profibus
- ▶ This equals the maximum number of eight TAGs ($4 + 4 = 8$).

5.3 Start the straton Runtime

The straton Runtime supports multi-instances and therefore needs parameters (transfer parameters), when it is started.

There are three possibilities in order to start the straton Runtime:

1. with the help of the zenon Runtime
2. with the help of the straton Runtime Manager
3. in a DOS Shell/BAT-file

START WITH THE HELP OF THE ZENON RUNTIME


In order to start the straton Runtime with the zenon Runtime:

- ▶ Select the straton project in the zenon Editor.

- ▶ Change the Start type (**Runtime**) as you wish. The properties of **Start type** are described in the embedded help in zenon.

START WITH THE HELP OF THE STRATON RUNTIME MANAGER

You can use the straton Runtime Manager to start the straton Runtime manually. You will find the straton Runtime Manager in the folder COPA-DATA in the Windows® start menu. The straton Runtime manager is used to start straton Runtime instances on a PC. You can for example chose *hard real time* here in order to start the straton real time version (straton RTK) or to start a straton Runtime instance during the booting of the system ("Auto start").



You receive accurate information about the individual elements of the straton Runtime manager by moving the mouse pointer over them. Then the corresponding help is displayed in the embedded help.

You receive the complete help about this application by clicking **?** in the menu bar.

START IN A DOS SHELL

The straton Runtime can be started in a DOS Shell or something similar (.bat file). For the command the following is true:

- ▶ all commands must be entered in capitals

- ▶ the following signs are allowed:

-

/

no sign

The following handover parameters are available:

MAIN PARAMETER:

Parameter	Description
<i>PORT=<number></i>	Communication port. Without parameters: 1200
<i>PORTTRACE=<number></i>	Event server point, Binding port. Without parameters: PORT+7800
<i>PATH=<DB-Path></i>	Storage area of the straton application code. Without parameters: straton Runtime directory
<i>ZENPATH=<Pfad></i>	zenon path (without meaning)
<i>ZENPROJECT=<name></i>	zenon project name (without meaning)
<i>DONTHIDE</i>	Do not hide the Runtime after the start (it is the only parameter without '=')
<i>STEP=<0 1></i>	Without parameters: no stepping mode. 0: no stepping mode 1: Start in stepping mode
<i>START=<0 1 2 3></i>	Without parameters: Warm start 0: Display setup dialog 1: Cold start 2: Warm start 3: Hot start
<i>LOWPRIORITY=<0 1></i>	Without parameters: low priority 0: low priority 1: Windows real time priority
<i>WRITELOG=<0 1></i>	Without parameters: Create log 0: Do not create log 1: Create log The log-file is created in the PATH directory as STRATONRTLOG.TXT.

ADDITIONAL PARAMETERS:

Parameter	Description
REMPATH=<Path>	Path for remanent data. Without parameters: PATH directory
DELAY=<number>	Start delay in [s]: Delayed start of the straton Runtime. Without parameters: 0
MAXUTILPRCT=<number>	Position of the slider for maximum PLC workload in %. Without parameters: 100

EVENT SERVER:

Settings equal to the settings under **Settings/Advanced** for the event server.

Parameter	Description
QSSYSTEM=<number>	Size of system queue. Without parameters: 1024
QSALARM=<number>	Size of alarm queue. Without parameters: 0
QSEVENT=<number>	Size of event queue. Without parameters: 8192
QSINFO=<number>	Size of info queue. Without parameters: 32768
NBEVENT=<number>	Maximum number of recordable events. Without parameters: 1024
EVENTCON=<number>	Number of possible event connections. Without parameters: 256

REDUNDANCY SETTINGS:


Parameters	Description
REDENABLE=<0,1>	Redundancy on/off. Without parameters: 0
REDADDR=<IP>	Redundancy partner address.
REDPORT=<number>	Redundancy port for replication.
REDCLITIMEOUT=<number>	Redundancy client time out [ms]; time out which is used to determine when a passive client becomes an active server. Without parameters: 1000
REDSRVTIMEOUT=<number>	Redundancy server time out [ms]; time out which is used to determine when the replication is stopped. Without parameters: 1000
REDZENON=<0,1>	If set to 1, the partner address is read from PROJECT.INI. Without parameters: 0

5.4 straton Runtime cycle

The straton Runtime cycle consists of:

- ▶ **Calc. time:** Time for data exchange, calculation, save calculated values, read and write modified values, idle time.
- ▶ **Cycle time:** Complete cycle time determined by system latency.
- ▶ **System latency:** Response time of the system.

These values can be displayed in the straton user interface. Use the shortcut Alt+S or Shift+Alt+A.




Property	Description
Binding exchange	Reading of the Binding values which are published in the network and which were configured by the application (if they were configured).
I/O exchange	Data exchange between the I/O drivers (except Modbus slave/server) and the I/O boards (if they were configured).
Application execution	Execution of the programs.
Digital sampling trace	Execution of the digital sampling (if it was configured).
Events	Sending of the events (Binding or straton32.exe driver of zenon) (if they were configured).
Forced values	Reading of the forced values of zenon from the straton Workbench (online debugging) and data exchange of the Modbus slave/server (if they were configured).
Sleep	<p>Wait the remaining time until the cycle time is over.</p> <p>When cycle setting is <i>As fast as possible (free run)</i>, the time is always 1 ms.</p> <p>The Sleep time is used in order to execute tasks of the operation system and of other</p>

	windows applications.
--	-----------------------

TIME ALLOCATION PLC AND WINDOWS

With the help of the slider in the straton Runtime user interface, you can determine how much time is reserved for the PLC and for Windows. The value displayed in the bar graph always refers to the ratio set in the slide control.



5.5 Close the straton Runtime

The straton Runtime can be closed manually either by using the context menu of the symbol in the system tray or by using the open window of the straton Runtime:

CONTEXT MENU SYMBOL

- Right clicking the icon in the system tray opens the following context menu:



- With a click on **End**, you open a dialog




- Clicking on **Yes** stops and closes the Runtime.

IN THE WINDOWS OF THE STRATON RUNTIME

Another possibility to close the Runtime is in the open window of the straton Runtime.

- The following menu opens after a click to the upper, left corner of the window:



- With a click on **End**, you open a dialog
- If you acknowledge the dialog, the straton Runtime is closed immediately.

Info

If the straton Runtime was started together with the zenon Runtime and for the straton project the start type 'autom. start/stop' was selected in the zenon Editor, the straton Runtime is automatically closed when the zenon Runtime is closed.

5.6 Remote systems

This chapter deals with target systems which are not on the local computer. The target system is accessed via Ethernet TCP/IP.

5.6.1 zenon Runtime and straton Runtime on one remote PC

INSTALLATION ON THE TARGET SYSTEM

First you install and license the zenon Runtime on the remote PC. The straton Runtime is automatically installed and licensed.

DOWNLOAD THE PROJECT DATA WITH STRATON RUNTIME, START TYPE "AUTOM. START/STOP" OR "AUTOM. START"

In order to download the zenon and straton Runtime files, use the Remote Transport function of zenon. You will find more information in the chapter Overview functions.

The straton Runtime is started and closed together with the zenon Runtime automatically.

DOWNLOAD OF THE APPLICATION DATA WITH THE STRATON RUNTIME START TYPE "START MANUALLY"

If the straton Runtime is started manually on the target PC (e.g. during boot up of the operating system), the PLC code has to be loaded manually to the target platform with the straton Workbench. For that

- ▶ enter the correct parameters in the property dialog **Workbench** in the zenon Editor: **Target host** and **Target port**
- ▶ in the straton Workbench click on the button **Online**
- ▶ with this the straton Workbench establishes a connection to the target system.
- ▶ now you can transfer the PLC code to the target system via button **Download**; the progress of the download is displayed with the help of a progress bar
- ▶ after the download the PLC starts automatically with the new application.

if the download was successful and the PLC program runs on the target system faultless, **RUN** is displayed in the tool bar

5.6.2 straton Runtime autarkic (PC)

INSTALLATION ON THE TARGET SYSTEM:

Install the straton on the target system with the autarkic installation.

START:

Before downloading the straton project, start it. The best way is to use the straton Runtime Manager. With this tool you can also carry out the settings so that the straton Runtime starts together with the operating system.

DOWNLOAD OF THE APPLICATION DATA WITH THE STRATON RUNTIME START TYPE "START MANUALLY"

If the straton Runtime is started manually on the target PC (e.g. during boot up of the operating system), the PLC code has to be loaded manually to the target platform with the straton Workbench. For that

- ▶ enter the correct parameters in the property dialog **Workbench** in the zenon Editor: **Target host** and **Target port**
- ▶ in the straton Workbench click on the button **Online**
- ▶ with this the straton Workbench establishes a connection to the target system.
- ▶ now you can transfer the PLC code to the target system via button **Download**; the progress of the download is displayed with the help of a progress bar
- ▶ after the download the PLC starts automatically with the new application.

if the download was successful and the PLC program runs on the target system faultless, **RUN** is displayed in the tool bar

5.7 straton Runtime with Real Time Kernel (RTK)

The straton RTK (Realtime Kernel) is the straton Runtime system for hard realtime. With that highest determinism and failure safety towards the operating system are guaranteed.


The straton RTK can only be started with the straton Runtime Manager (flag Hard realtime has to be activated) or in a DOS-Shell/BAT-file.

Attention:*Only one instance of the straton RTK can be started at a time.*

The straton RTK is only available for the Windows operation systems XP (XPe) and VISTA.

The Realtime Kernel is designed, so that it triggers the straton Runtime cycle independent of Windows. So the straton Runtime cycle is guaranteed to be executed deterministically. Cycle times must be 100 µs or higher.

The PC's part of the calculating capacity can be set with a slider.



Depending on the size of the PLC application and the defined cycle time the slider has to be adjusted to the PLC load. The slider can be set between 10% and 85%. The current load (bar) indicates whether the allowed maximum for executing the PLC cycle is sufficient.

If the bar is near 100%, there is a danger of cycle overflows! In this case set the slider higher (towards 85%). If this is not possible because of the applications in Windows (e.g. bad screen opening times of zenon) the cycle time of the straton application has to be increased.

Attention

If the bar reaches the 100% mark, there is a danger of cycle overflows!

Examplee

Slider at 10%, cycle time 10ms:

The straton RTK must process the PLC program in 1 ms which equals 10% of the set cycle time of 10 ms.

Slider at 50%, cycle time 5ms:

For executing the PLC program 2.5ms are available for the straton RTK.

Slider at 85%, cycle time 20ms:

For executing the PLC program 17ms are available for the straton RTK.

The following formula can be used to find out, if the setting of the slider does not lead to cycle overflows in combination with the cycle time:

*cycle time > (100 / Sliderposition [%]) * calculating time*

In order to find out the calculating time of the PLC cycle, click Shift+Alt+A and note the value Max. Cal. Time [μs].

Assumption:

Max. cal. time: 274μs


Slider position: 50%

Set cycle time: 1ms (1000μs)

Calculation:

$$(100/50) * 274 = 548 \mu s$$

This means that the defined cycle time of 1 ms is sufficient.



Attention

Please keep in mind: If you do not stick to the described formula, the determinism which is based in the cycle time is not given anymore!

DESCRIPTION OF THE DISPLAYED MEASURING VALUES (SHOW WITH ALT+S RESP. SHIFT+ALT+A):

System latency (Alt+S)	
Current [μs]	Current system latency (<i>see also Runtime cycle</i> (on page 38))
Maximum [μs]	Maximum system latency (since the start of the Runtime)

Extended statistic (Shift+Alt+A)	
Cal. time [μs]	Current calculation time of the last cycle
Max. cal. time [μs]	Maximal calculation time for a PLC cycle (since the start of the Runtime)
Cycle time [μs]	Current cycle time
Min. cycle time [μs]	Minimal cycle time (since the start of the Runtime)

Max. cycle time [μs]	Maximal cycle time (since the start of the Runtime)
Cycle overflow [1]	Counter for cycle time exceedance (since the start of the Runtime)
Driver overflow [1]	Counter for failed PLC cycles of Windows (non-realtime) drivers (since the start of the Runtime)

The value of the cycle time can always only be a multiple of the HAL Timer Period (time basis). The time basis depends on the selected timer and its time basis (see also *straton RTK configuration* (on page 49)). That means: A set cycle time of 10 ms of a hardware with a time basis of 122 μs is not executed with exactly 10,000 ms but with 10,004 ms.

5.7.1 Restrictions and requirements of the straton RTK

HARDWARE REQUIREMENTS FOR THE STRATON RTK

ACPI:

The hardware (PC or IPC) and the operating system (Windows® XP, XPe or Vista) must support ACPI:

- ▶ ACPI-Multiprocessor-P
- ▶ ACPI-PC (Advanced Configuration and Power Interface)
- ▶ ACPI-Uniprocessor-PC

You can check whether your PC supports ACPI in the system control (system/device manager/computer).

CPUS:

The straton RTK is supported from the following processor generations on:

- ▶ Pentium II or younger
- ▶ AMD Athlon XP or younger

LIMITATIONS

The straton Real Time Kernel (RTK) runs as a separate process on the hardware level independent of the operating system. The straton Runtime runs on Windows®. The real-time-enabled straton RTK has a few restrictions compared to the straton Runtime.

FUNCTION BLOCKS:

The following function blocks are not processed directly in the Kernel Mode, but only emulated:

- ▶ all file operations (category 'Files')
- ▶ all TCP/IP modules (category 'TCP-IP')

Following function blocks are not supported by the straton RTK:

- ▶ day_time_local (Category 'Clock')

Info

In order to determine exactly which function blocks the straton standard library supports, use the feature of the configuration of the straton Workbench (main menu: Project/Configuration/Upload).

After you have selected the configuration, the function blocks which are not supported are marked red in the library.

I/O DRIVER

The following straton I/O drivers are executed by the straton RTK in Kernel Mode (real time):

- ▶ Profibus (Hilscher CIF Profibus)
- ▶ Hilscher SYCON universal (Hilscher SYCON configuration)

You can find more information about supported I/O drivers here: **straton I/O driver support** (on page 68)

REGISTER AND DE-REGISTER REAL TIME DRIVERS

There is a small chance that the real time driver of the straton RTK must be registered and de-registered manually. In order to do this start the command prompt via:

Start > execute > cmd.

Use the following syntax:

- ▶ Register:

```
<Directory of the straton RTK>:\ stratonrtkvm -regsvr
```

- ▶ De-register:

```
<Directory of the straton RTK>:\ stratonrtkvm -unregsvr
```

Example of the <directory of the straton RTK>: C:\Program Files\COPA-DATA\zenon651

5.7.2 straton RTK configuration

The straton Real Time Kernel (RTK) runs as an own instance on hardware level and is independent of the operating system. The Timerticks which are used for control are directly obtained from the motherboard. Which timer are available depends on the used hardware. The configuration is carried out by the straton RTK configurator.

Start RTK configuration

Double click the button for straton RTK Configurator in the windows control panel.



The window for editing the configuration opens. In the left window you see a menu tree with the following options:


- ▶ CDrtHAL configuration
- ▶ Basic settings
- ▶ Taskmanager

- ▶ Hardware configuration
- ▶ Access to the physical memory
- ▶ Log messages

In the right-hand window you can see information about the menu items and configure the RTK.

RTK basis information

After the start menu item 'CDrtHal configuration' is active in the left-hand window of the configuration software. In the right-hand window displays basic information about the configuration and the system:




Property	Information
Version	Version of the real time driver (CDrtHAL).
Status	RTK is active or inactive
Interrupt controller	Type of interrupt controller.
High precision event timer	Support depends on hardware: PCs certified for Windows Vista support this function.
Process cores	Number of available process cores.

RTK basic settings

RTK BASIC SETTINGS

In the basic setting you define the following:

- ▶ Source for the Timertick
- ▶ CPU on which the RTK is carried out
- ▶ Basic time as basis for the multiplication factor for the calculation of the cycle time



TIMER FOR REAL-TIME SOURCE

Which time is displayed on the selection list depends on the used hardware. This information is also displayed on the start page of the RTK configuration. Available can be:

- ▶ Interrupt-Controller APIC
- ▶ Interrupt-Controller PIC
- ▶ HPET (High precision event timer)


The following possibilities arise from this:

1. PIC without HPET
 - Timer (8254 Timer), basic times: 334 μs, 143 μs, 112 μs, 53 μs
 - Profiles (real-time clock), basic times: 488 μs, 244 μs, 122 μs
2. APIC without HPET

- Profiles (real-time clock), basic times: 488 µs, 244 µs, 122 µs
 - Profiles (local APIC), basic times: choose anywhere between 50 - 500 µs
 - Unused (8254 Timer), basic times: choose anywhere between 50 - 500 µs
3. APIC with HPET and Windows VISTA
- Timer (HPET timer 0), basic times: 500 µs, 250 µs, 125 µs
 - Profiles (local APIC), basic times: choose anywhere between 50 - 500 µs
 - Unused (HPET timer 2), basic times: choose anywhere between 50 - 500 µs

Whether and to what extend basic times are available depends on the hardware (real-time clock) and the operating system. When using the 'timer' real-time source, the source for the Windows Timer Interrupt is used for the real time execution. In this case the set basic time must be an integral factor of the Windows Timer Interrupt basic time.

Real time source: depends on the operating system Select using list field (drop down).



We recommend the following basic setting: Unused (HPET Timer2).

Real time CPU: Select the CPU on which the process of the RTK should be carried out.

Basic time: Basic time of the timerticks. Depending on the real time source, the basic time is selected from a list or entered freely. During operation the multiplication factor for the timer ticks refers to the entered basic time.


Attention

When using Profile: real time source the kernel profiling must not be activated under any circumstances as long as a straton RTK application is executed. For more information about kernel profiling see:

[*\(http://www.microsoft.com/downloads/details.aspx?familyid=9d467a69-57ff-4ae7-96ee-b18c4790cff&displaylang=en\)*](http://www.microsoft.com/downloads/details.aspx?familyid=9d467a69-57ff-4ae7-96ee-b18c4790cff&displaylang=en)

RTK Taskmanager

The task manager displays cycle times and execution times.




Property	Information
Cycle time (in microseconds)	Minimal, maximal and current value. Cycle refers to the cycles of the Timerticks based on the basic time.
Execution time (in microseconds)	Minimal, maximal and current value.

RTK hardware configuration

A separate reserved storage area is needed for the communication with the I/O drivers (e.g. Profibus) which are executed in the kernel mode. straton RTK and the I/O driver system agree on an area on which both have read and write access.


The configuration offers three settings:



Options	Effect
Generally prohibit access to the physical memory.	Free access memory areas are a safety risk with regards to malware. Thus access to the physical memory is prohibited in the shipping state. Basic setting.
Generally allow access to the physical memory.	Allows the communication to use the whole memory, straton RTK und Profibus set their communication areas randomly. Unsafe setting which is not recommended.
Allow access to a defined physical memory area.	. straton RTK and I/O driver have a strictly allocated memory area. Recommended setting

Define memory area


In order to allocate a fixed memory area for straton and I/O driver, click on **Access to the physical memory** in the left window and then on **Allow access to defined physical memory area** in the right selection window.



Property	Information
Range	The number is assigned by the configurator automatically.
Basic address	Start address for the free memory. It can for example be determined with the help of the Hilscher Tool (included in the delivery of the card).
Length	Length of the free area. Attention: must be stated in Bytes.
Add	Creates a new entry in the list.
Remove	Deletes an existing entry from the list.

RTK Logs

Messages from the RTK are displayed in the area **Log messages**.



Property	Information
Date/Time	When did the event happen
Type	What type of message (status, error, ...)
Description	What has happened?

Close RTK configuration

By clicking button **OK** all changes are saved and the configurator is closed. If the system needs to reboot, a corresponding message is displayed.

If you close the configurator by clicking the close symbol (**X**) or by clicking **Cancel**, a dialog appears asking whether you want to save the changes.

5.7.3 Blue Screen Handling

A probable Bluescreen of Death (BSOD) is recognized by the straton RTK immediately.

If the straton RTK is configured for stopping in case of a BSOD, the shut down program - if defined - is executed immediately, i.e. before the theoretically next cycle.

If the straton RTK is configured to continue running, the next cycle is executed after a short delay of ca. 10 ms (switching the graphics mode).

In order to achieve this, the straton function **RTK_OnBugCheck** of the straton standard library must be set to TRUE in the straton application.

Attention

In case of a BSOD the execution of the straton application can be limited.

Following functions are no longer supported when this occurs:

File operations, TCP functions, functions of the serial interface, no real time field bus driver, system clock functions, RETAIN variables, writing log messages (changes reserved by product version cycles).

*In order to check in the straton application if a BSOD has occurred, use the straton function **RTK_IsBugCheck**.*

SYSTEM REQUIREMENTS FOR SMOOTH CONTINUOUS RUNNING AFTER A BSOD:

- ▶ Windows® XP SP2 or higher (e.g. Vista)
- ▶ Pentium 3, 4 or M (Centrino) or higher

OPTIONS FOR PROFIBUS MASTER (HILSCHER CIF PROFIBUS):

No restart after stop (keeping outputs): If this option is active, the outputs of the Profibus I/Os remain set after the shut down. Otherwise the outputs would be set to the defined alternate values after the shut down sequence.

5.7.4 Error codes when starting stratonRTK

The displayed error code refers to starting the STRATONRTKVM.exe.

Error code	Meaning
------------	---------

0x00000000	If an error occurred in the straton RTK, usually the error is explained in a message: The log message with the error code 0x00000000 can be ignored.
0xFFFFFFFF	A timeout occurred on starting the STRATONRTKVM.exe. Possible reasons: STRATONRTKVM.exe does not exist, too high load of the system. Attention: After such an error make sure that the STRATONRTKVM.exe as well as the STRATONRTK.exe no longer run (task manager) before you restart STRATONRTK.
0x00000001 – 0x0000FFFF	Is an error code of the straton virtual machine (COPALP error message).
0xFFFF01, 0xFFFF02	Error loading the non-realtime bus drivers: probable reason: incompatible (old) version of one or more bus driver(s).
0xFFFFF000	rtHAL error code (0xFFFFF000 is added to the rtHAL code)
0xFFFFF001	Make sure, that the rtHAL driver has been installed correctly. If the problem still exists, contact your zenon support and tell them the Windows version (service pack, hot fix, ...) and the used Windows HAL. The name of the used HAL is shown in the device manager under computer. System requirements: ACPI, Pentium II or AMD Athlon or higher.

RTHAL ERROR CODES:

0x0	No error
-----	----------

POSSIBLE ERROR CODES ON STARTING

Error code	Meaning
0x1	Error while loading the driver. Reason: Driver is not registered correctly.
0x2	START could not be executed. Reason: Wrong version of the driver is installed.

ERROR CODES DURING RUNTIME

Error code	Meaning
0x6	SUSPEND could not be executed.

0x7	STOP could not be executed.
-----	-----------------------------

INTERNAL STRATON VIRTUAL MACHINE ERROR CODES

```

#define T5RET_OK 0
#define T5RET_ERROR 1
#define T5RET_BADCODE 2 /* invalid app code - bad header */
#define T5RET_BADCODETARGET 3 /* invalid code - bad target id */
#define T5RET_BADCODEVERSION 4 /* invalid code - bad version */
#define T5RET_EXECSIZE 5 /* exec buffer overflow */
#define T5RET_BADREQUEST 6 /* unknown comm request */
#define T5RET_SERVERREAD 7 /* cannot process read request */
#define T5RET_UNKNOWNNTIC 8 /* unknoxn tic code */
#define T5RET_DATA8OVERFLOW 9 /* too many DATA8 used */
#define T5RET_DATA16OVERFLOW 10 /* too many DATA16 used */
#define T5RET_DATA32OVERFLOW 11 /* too many DATA32 used */
#define T5RET_DIVZERO 12 /* division by 0 in TIC (32bit) */
#define T5RET_TIMEOVERFLOW 13 /* too many TIME variables */
#define T5RET_CANTACTIME 14 /* active timers not supported */
#define T5RET_SAFETICLOOP 15 /* awful loop in TIC (safe mode) */
#define T5RET_OUTOFTIC 16 /* TIC code ointer out of range */
#define T5RET_UNKNOWNSTF 17 /* not supported std function */
#define T5RET_LDIVZERO 18 /* division by 0 in TIC (64bit) */
#define T5RET_DATA64OVERFLOW 19 /* too many DATA64 used */
#define T5RET_STRINGOVERFLOW 20 /* too many strings */
#define T5RET_SDIVZERO 21 /* division by zero in TIC (8 bit) */
#define T5RET_WDIVZERO 22 /* division by zero in TIC (16 bit) */
#define T5RET_HOTRESOURCES 23 /* HOT restart: system resources used */
#define T5RET_HOTMAP 24 /* invalid var map in hot restart */
#define T5RET_HOTACTIME 25 /* change of active timer map */
#define T5RET_HOTSTAMP 26 /* bad build stamp for hot restart */
#define T5RET_HOTSFC 27 /* SFC changed - no hot restart! */
#define T5RET_HOTRETAIN 28 /* retain def has changed - no hot */
#define T5RET_HOTFORMAT 29 /* bad DB format - no hot restart! */
#define T5RET_CYCLEOVERFLOW 30 /* cycle time overflow */
#define T5RET_RETAINSTORING 31 /* cant store retain variables */
#define T5RET_ARRAYBOUND 32 /* array index out of bounds */
#define T5RET_RECURSE 33 /* recursive call of sub-program */
#define T5RET_XOVERFLOW 34 /* too many external variables used */
#define T5RET_NOBSAMPLING 35 /* sampling trace not supported */
#define T5RET_TASKOVERFLOW 36 /* too many tasks */
#define T5RET_HOTCALLSTACK 37 /* call stack overflow (hot) */
#define T5RET_STACKOVER 38 /* stack overflow */
#define T5RET_HOTASI 39 /* cannot hot restart ASi */
#define T5RET_TOXC 40 /* OXC limit reached */
#define T5RET_WOXC 41 /* OXC info */

```

5.8 Redundancy straton and zenon

straton can be used redundantly and offers the possibility to combine the zenon redundancy with the straton redundancy.

In this chapter the configuration of the zenon/straton redundancy is described. The zenon/>CA_PRODUCTNAME< redundancy is referred to as SCADA logic redundancy from here on.

Further terms:

- ▶ zenon server = dominant zenon server
- ▶ zenon SB = zenon standby server
- ▶ Active straton Runtime = straton Runtime instance being executed
- ▶ Passive straton Runtime = backup system (Standby) of straton Runtime

OPERATING SYSTEMS

Redundancy can be used with the following operating systems:

- ▶ Windows XP
- ▶ Windows Vista
- ▶ Windows 7
- ▶ Windows CE

5.8.1 Requirements

Two PCs are necessary for SCADA logic redundancy. The both PCs are connected via Ethernet TCP/IP (100 MBit, recommended 1 GBit).

Attention

The SCADA logic redundancy demands that both systems, zenon and straton, are installed on one PC.

We recommend to set the cycle time of the straton project to twice the cycle time of a single project, but at least to 50 ms.

Since SCADA logic implies that straton and zenon communicate with each other using the shared memory driver (straton to zenonRT connection), it must be guaranteed that the zenon server and the active straton Runtime run on the same PC.

In order to prevent a one-sided switching from straton or zenon, a synchronization between the straton Runtime and the zenon Runtime must be engineered. For this a watchdog is used.

WATCHDOG

STRATON

The status of the zenon project (stand alone/server/standby server/client) is transferred via the shared memory command area and is evaluated by the redundancy function block. It has a freely definable time out value as input. As output binary values for redundancy switch and active, passive and failed Runtimes etc. are output. They determine the reaction of the straton Runtime.

To make it clear from which zenon project the watchdog or the status originates,


- ▶ the zenon Runtime driver or the shared memory area must have the zenon project GUID
- ▶ the zenon Runtime driver or the shared memory area must have the straton project name

ZENON

A watchdog generated by the zenon Runtime driver is transferred via the shared memory command area and evaluated in zenon. This evaluation takes place in accordance with the settings of properties **Failure recognition after [s]** and **Function for failure recognition**. They define a time out time and a function (normally **Exit Runtime**).

In order for the correct watchdog to be evaluated, it must be clear for several active straton projects from which straton project the watchdog originated. For this:

- ▶ the zenon Runtime driver or the shared memory area must have the straton project name



 Attention

The start of the zenon Runtime must not be performed from the zenon Editor but with a direct call from the zenon Runtime!

The zenon redundancy must be set up. Details: See help chapter Network.

5.8.2 Configure redundancy

straton and zenon can control each other in redundant operation by means of a watchdog. If the straton Runtime fails:

- ▶ the local zenon Runtime is also closed
- ▶ both systems are switched to redundancy mode

CONFIGURATION IN ZENON

To activate redundancy:

- ▶ activate property **Redundant operation** in group **Runtime** of the properties of the straton project in zenon
- ▶ define
 - **Failure recognition after [s]**
 - **Function for failure recognition**

STRATON

The settings for redundancy are made in tab **Redundancy** (on page 29) auf the driver settings.

WATCHDOG

With the watchdog each side checks the other for changes to this counter. If the counter for a projected time is not changed, this is reported to the program:

- ▶ zenon: a function configured in an integrated project is carried out (**Function for failure recognition**)
- ▶ straton: A function block output becomes active

The watchdog examination starts as soon as the other side has changed its watchdog for the first time. This is necessary because the time is needed to start or the straton Runtime does not necessarily need to start with the zenon Runtime.

Info

If straton Runtime is started manually, the following **command line settings** (on page 34) must be made:

- ▶ zenon path:
`ZENPATH=<Path>`
- ▶ Name zenon project:
`ZENPROJECT=<name>`
- ▶ Information on zenon network project:
`REDENABLE=<0,1>`

REDZENON=<0,1>

WATCHDOG IN ZENON

zenon checks straton Runtime Watchdog if:

- ▶ straton Runtime executes code, timeout is > 0 and Runtime can be assigned to an integrated straton project
- ▶ straton Runtime is stopped
- ▶ straton Runtime is passive or started passively
- ▶ straton Runtime is ended and was previously passive or active

FUNCTION FOR RECOGNIZING FAILURES

With the **Function for failure recognition** property, a function is selected that is executed as soon as the time-out defined in **Failure recognition after [s]** for the watchdog has expired. The watchdog is only rechecked if Runtime is registered again.

If a function from another project is used, the project must already have been loaded when the project with the integrated straton project is loaded.

LOGGING

The straton zenRt driver connection can be logged with the diagnosis Viewer. The module name is straton. Each message contains the name of the zenon project and the name of the straton project. The logging includes:

- ▶ Error
 - zprj:<z-project> sprj:<s-project> Runtime <Runtime Process ID> watchdog expired.
Runtime watchdog was not operated by Runtime for too long.
 - zprj:<z-project> sprj: <s-project> Runtime: <Runtime process ID> Unknown straton project.
straton Project cannot be assigned to an integrated zenon project.

- ▶ Warnings
 - vm: <Vm process ID> zenon project '<Name>' unknown
Name of the straton projects is not known in zenon.

WATCHDOG IN STRATON RUNTIME

If the zenon time-out failure recognition is > 0 , the zenon watchdog is checked on an ongoing basis. This check takes place if:

- ▶ Code is executed
- ▶ Runtime is active or passive.

ZENRT_RED FUNCTION BLOCK

The number of switch attempts count up in the time-out cycle. If the straton Runtime project cannot be assigned to a zenon network project, the network timeout time (**Timeout [s]** property in **Network** group) is added to the failure recognition time (**Failure recognition after [s]** property). The time that the **ERROR** output is active is now no longer **MAX_SWITCH * cycle** but **MAX_SWITCH * timeout [+ network timeout]**.

The non-process-handling, non-dominant zenon computer is considered a standby server.
The non-process handling, dominant computer (server starts as standby) is not considered a standby.

5.9 OEM spezifikation

In this OEM specification the possibilities of the COPA-DATA straton Runtime are described which are referred to in the straton Workbench help with "see OEM specification".

CONFIGURATION (PROJECT PROPERTIES)

As a standard the straton Workbench contains several features and an extensive library of functions and function blocks.. Depending on the Runtime configuration, some features or blocks may be not available. Therefore it is possible to select configurations for the Workbench in order to highlight the features which are not supported by the Runtime.

In the straton Workbench a list of this configurations is available under *Project -> Configuration...*. This can change with the product/version cycle.

FILE ADMINISTRATION FUNCTION (FUNCTION BLOCKS)

This function makes it possible to read and write files sequentially.

The following functions are supported by straton Runtime versions

- ▶ CE
- ▶ RT (PC)
- ▶ RTK (PC)

and are implemented **not blocking**:

`F_ROPEN, F_WOPEN, F_AOPEN, F_CLOSE, F_EOF, FA_READ, FA_WRITE, FM_READ, FM_WRITE,
FB_READ, FB_WRITE, F_EXIST, F_GETSIZE, F_COPY, F_DELETE, F_RENAME, LogFileCSV`

The following functions are only supported by straton Runtime versions

- ▶ CE
- ▶ RT (PC)

and are implemented **not blocking**:

`F_EXIST, F_GETSIZE, F_COPY, F_DELETE, F_RENAME`

The possible paths vary depending on the operation system (XP,Vista). Keep in mind that under Windows Vista some directories are write-protected if the UAC (User Account Control) is activated.

SFC EXECUTION

The execution of the SFC program equals that of a T5 standard target system und follows the information of the straton Workbench help.

The exclusiveness of transitions within a divergence is supported.

INTERLINK APPLICATIONS - BINDING

A maximum of 65535 Binding variables can be published in the network. However this value is reduced by every variable which is sent to zenon using the event service.

The standard IP port number of a straton Runtime is 9000.

PROJECT PROPERTIES - "C" COMPILER

This feature is supported by all straton target systems (RT, CE, RTK). All C compilers which are normally proposed by the straton Workbench can be used. **Attention:** Only use the default name of the created Runtime-DLL.

LOGFILECSV (FUNCTION BLOCK)

See first point: File administration function (function blocks).

ADDITIONAL OEM RELEVANT FEATURES AND FUNCTIONS:

Feature	RT (PC)	RTK (PC)	CE
DTAT (function block)	x	x	x
TCP/IP management functions	x	x	x
Dynamic memory allocation function	x	x	x
PrintF (function)	x	x	x
Step by step debugging	x	x	x
Functions for real time clock administration	x	x	x
Digital sampling recording	x	x	x
UDP management function	x	x	x
T5 registry management functions	-	-	-
DTFORMAT (function)	x	x	x
GETSYSINFO (function) - _SYSINFO_CYCLESTAMP_MS	x	x	x
Variable status bits	x	⁻¹	x
DAY_TIME (function)	x	x	x

Key:

x: Supported

-: Not supported

1: Driver which support the variable status bits are only emulated or not supported by the straton RTK. Therefore no access is granted to the status bits or the time stamps.

RETAIN VARIABLES (=REMANTENT FLAGS)

The straton Runtime from COPA-DATA saves its RETAIN variables after every cycle if a value changed. The place where data is stored can be varying. Normally the values of the RETAIN variable are saved in the instances path (handover parameter PATH). Depending on the system, it can be the hard disk or a flash card.

Some straton I/O drivers support saving the RETAIN values to the SRAM (battery buffered RAM), e.g. the ThinkIO/System758 driver.

In order for the RETAIN values to be loaded when the PLC application is restarted, the straton Runtime must be started with the corresponding handover parameters/settings (cold start - load RETAIN variables).

I/O DRIVER

You can find more information about supported I/O drivers here: *straton I/O driver support* (on page 68)

You can find information about the support of Online Change or Hot Restart here: *straton I/O driver: Hot-Restart/Online Change* (on page 70)

5.10 straton I/O driver support

I/O drivers which are supported by different straton Runtime types:

Drivers	RT (PC)	RTK (PC)	CE
Advantech ADAM 5550	-	-	-

Anybus Configuration	X	E	-
ApplicomIO Configuration	X	E	-
AS-interface	X	-	-
BECKHOFF CX1000	-	-	X
Brodersen IOTOOLS	X	E	-
CAN-bus	-	-	-
Hilscher CIF Profibus	X	X ¹	X
Hilscher SYCON Configuration	X	E	X ²
Hilscher SYCON Configuration [universal]	X	X	X
Hilscher SYCON.net Configuration	X	E	-
IEC 60870 Slave	X	-	X
IEC 61850 Client	X	E ¹	X
IEC 61850 Server	X	-	X
Interbus-S	X	E	-
MODBUS Master Protocol	X	E	X
MODBUS Slave Protocol	X	E	X
PROFINET IO	X	E	X
SoftNet ProfibusDP	X	E	-
straton to zenon Runtime connection	X	-	X
ThinkIO/IO System 758	-	-	X
Wago 750-860	-	-	-
Weihenstephan Standard - Client	X	E	X
Win32 Shared memory	X	-	-

XFlow	-	-	-
--------------	---	---	---

LEGEND

x: Fully supported

-: Not supported

E: Carried out as emulation (performance loss possible, determinism is limited in the PLC cycle, driver selection at a BSOD)

1: The driver specific function blocks do not work under straton RTK.

2: Hilscher DLLs must be available on the target platform.

5.11 straton I/O driver: Hot-Restart/Online Change

The straton I/O drivers support the Hot-Restart or Online Change in different ways:

Drivers	Hot-Restart	Online Change	Online Change including change of the bus driver configuration
Anybus Configuration	x	x	x ¹
ApplicomIO Configuration	x	x	x ¹
AS-interface	x	x	x ¹
BECKHOFF CX1000	x	x	-
Brodersen IOTOOLS	x	x	x ¹
Hilscher CIF Profibus	x	x	-
Hilscher SYCON Configuration	x	x	x ¹
Hilscher SYCON Configuration [universal]	x	x	x ¹
Hilscher SYCON.net Configuration	x	x	x ¹

IEC 61850 Client	x	x	-
Interbus-S	x	x	-
MODBUS Master Protocol	x	x	x ¹
MODBUS Slave Protocol	x	x	x ¹
PROFINET IO	x	x	-
SoftNet ProfibusDP	x	x	x ¹
straton to zenon Runtime connection	x	x	- ²
ThinkIO/IO System 758	x	x	-
Weihenstephan Standard - Client	x	x	x ¹
Win32 Shared memory	x	x	x ¹

LEGEND

x: Functionality available

-: Functionality not available

1: Online Change including the change of the bus driver configuration is always followed by the reinitialization of the I/O driver. Because of the reinitialization I/Os can fail for a short period!

2: No need for change in the bus driver configuration.

6. straton Runtime Manager

The straton Runtime Manager administrates all straton Runtime projects, which are stand alone or must be started manually, on your computer. It does not matter whether there is a zenon Runtime installed on the computer.

6.1 Why should you use the straton Runtime Manager?

- ▶ If you created your straton project in zenon and you set the zenon property of the straton project RT start type to *start manually*, the straton Runtime Manager is the ideal tool for organizing the parameters for the manual start.
- ▶ If you want to start your straton Runtime project during the booting of the Windows operating system, you can set this with one mouse click in the straton Runtime Manager.
- ▶ If you want to reorganize your straton project, you can do this with the straton Runtime Manager.
- ▶ If you want to run the straton Runtime autarchically (without the zenon Runtime), it is best to call up the straton Runtime instance using the straton Runtime Manager.

6.2 Main menu

- ▶ Configurations: There you can administrate the straton Runtime projects
- ▶ Languages: There you can switch between languages online
- ▶ Settings: Enter the path of the straton Runtime
- ▶ ?: Open the help
- ▶ Exit: Exits the program - **Hint:** Do not forget to save the settings before you exit the straton Runtime Manager!

6.3 Properties help

Place the mouse cursor over an element in the straton Runtime Manager in order to see the corresponding help text in the property help.

In addition all elements of the straton Runtime Managers are described here:

6.3.1 Configuration list

This list contains all available straton Runtime configurations.

Click on an entry in the list in order to display its parameter settings.

After that click on **Edit** in order to change the parameters.

Click on **Save** in order to save the changes.

6.3.2 straton project folder

The selected path of the straton Runtime project (storage location of the PLC code) is entered there automatically. You can change this entry manually by left-clicking the folder symbol.

 **Info**

*Before you are able to edit any setting which you have already saved, you must first select the concerning configuration in the list. After that click on button **Edit**. In order to save the changes, click on button **Save**.*

6.3.3 Name of the configuration

The name of the last path of the straton Runtime files is entered automatically if a new configuration is created. You can changes this name freely.

 **Info**

*Before you are able to edit any setting which you have already saved, you must first select the concerning configuration in the list. After that click on button **Edit**. In order to save the changes, click on button **Save**.*

6.3.4 Port (Main)

Enter the main port for the straton Runtime instance. This port defines the connection of the straton Workbench and a zenon drivers. Per default this port is set to 1200.

 **Info**

*Before you are able to edit any setting which you have already saved, you must first select the concerning configuration in the list. After that click on button **Edit**. In order to save the changes, click on button **Save**.*

6.3.5 Port (Binding)

Enter the binding port for the straton Runtime instance. The binding port defines the connection for spontaneous TCP/IP communication to other straton Runtimes. Per default this port is set to 7800 higher than the main port.

 **Info**

*Before you are able to edit any setting which you have already saved, you must first select the concerning configuration in the list. After that click on button **Edit**. In order to save the changes, click on button **Save**.*

6.3.6 Startup

Define the startup behavior of the straton Runtime instance.

- ▶ Cold start - The straton Runtime starts with initialized variables.
- ▶ Cold start (load RETAIN variables) - The straton Runtime starts initialized with remanent markers.
- ▶ Hot restart - The straton Runtime starts with the variable values from the time the Runtime was stopped.



*Before you are able to edit any setting which you have already saved, you must first select the concerning configuration in the list. After that click on button **Edit**. In order to save the changes, click on button **Save**.*

6.3.7 Start in step mode

In order to start the straton Runtime in step mode, activate this checkbox.



*Before you are able to edit any setting which you have already saved, you must first select the concerning configuration in the list. After that click on button **Edit**. In order to save the changes, click on button **Save**.*

6.3.8 Windows real time priority

In order for the straton Runtime instance to run in the Windows real time priority, activate this check box.

 **Info**

We recommend to always have the real time priority activated. First and foremost deactivating the real time priority is used for testing purposes (e.g. if there may be infinite loops).

 **Info**

*Before you are able to edit any setting which you have already saved, you must first select the concerning configuration in the list. After that click on button **Edit**. In order to save the changes, click on button **Save**.*

6.3.9 Hard real time

If you activate this checkbox, the straton real time PLC (straton RTK) is called up when the configuration is started. As the straton real time PLC may only run once on the computer, it is validated that this checkbox is only activated for one configuration.

 **Info**

*Before you are able to edit any setting which you have already saved, you must first select the concerning configuration in the list. After that click on button **Edit**. In order to save the changes, click on button **Save**.*

6.3.10 Report output

Activate this checkbox in order to activate the writing of messages of the Runtime in a log file.

 **Info**

Writing a log file will influence the performance.

 **Info**

The log file is named "straton RTLOG.txt" and is saved in the straton Runtime project folder.

 **Info**

*Before you are able to edit any setting which you have already saved, you must first select the concerning configuration in the list. After that click on button **Edit**. In order to save the changes, click on button **Save**.*

6.3.11 Auto start

In order to start a straton Runtime instance directly with the booting of the Windows operating system, activate this checkbox.

 **Info**

*Before you are able to edit any setting which you have already saved, you must first select the concerning configuration in the list. After that click on button **Edit**. In order to save the changes, click on button **Save**.*

6.3.12 Button "New"

If you want to create a configuration, click on button **New**. After that a dialog opens in which you can select the folder in which you want to save the <CA_PRODUCTNAME> Runtime files (the PLC code). Confirm your selection with **OK**. You can change the name of the configuration. In order to save the configuration and the name of the configuration, click on **Save**.

6.3.13 Button "Edit"

Before you can change the parameters of a configuration, you must click on button **Edit** after you have selected an entry from the configuration list. In order to save the changes, you must click on **Save**.

6.3.14 Button "Save"

Click on button **Save** in order to save all changes.

6.3.15 Button "Delete"

In order to delete a configuration, select the entry from the configuration list and click on button **Delete**.

6.3.16 Button "Start"

In order to start the straton Runtime with the respective configuration, select a configuration from the list and click on button **Start**. The straton Runtime starts immediately.

 **Info**

If the folder of the configuration does not contain any straton Runtime files (PLC code), the straton Runtime starts in mode No program.

6.3.17 straton Runtime (settings)

Enter the folder of the straton Runtime (folder of stratonRT.exe). In order to browse through your hard disk, left-click the folder symbol.

6.3.18 Language selection (languages)

Select the desired language by clicking on the respective flag.

6.3.19 Show splash screen (setting)

If you activate this check box, the splash screen of the straton Runtime Manager is displayed at the start.